

GIACOMINI S.p.A. Tel. (+39) 0322 923111 Fax (+39) 0322 96256 info@giacomini.com www.giacomini.com

Sede legale ed amministrativa: Via per Alzo, 39 - 28017 San Maurizio d'Opaglio (NO) ITALIA R.E.A. della CCIAA di Novara n. 194845 PIVA 01792290031 - Codice Fiscale 01856080062 Identificativo IVA IT 01792290031 Capitale Sociale: € 50.666.520 i.v. Società soggetta a direzione e coordinamento della Alberto Giacomini Holding S.a.s. di Alberto Giacomini



San Maurizio d'Opaglio, 12/04/2019

SUPPLIER CONFORMITY DECLARATION

(according to ISO/IEC 17050-1)

Giacomini S.p.A. company, manufacturer of components for heating, cooling and sanitary distribution systems, located in Italy, San Maurizio d'Opaglio (NO), via per Alzo n. 39, whose design and production processes comply with the requirements of the UNI EN ISO 9001:2015 standard,

STATES that

the crosslinked polyethylene pipes (Pe-X) GIACOFLEX and GIACOTHERM series

R993, R994, R995, R995B, R955R, R996 and R996T

have been properly designed and manufactured, in compliance with EN ISO 15875 standard, and are subjected to the analysis of the mechanical resistance, for cyclic loads of temperature and pressure, following the same procedures expected for pipes manufactured in Pe-Xa and Pe-Xc.

The silane crosslinking method, used for the production of pipes made of Pe-Xb, furthermore allows obtaining the improvement of the chemical and physical characteristics: in this crossslinking method, the dye, the antioxidant stabilizers and the UV rays stabilizers have no influence on the material ability to crosslink (as it happens on the contrary for other methods), by ensuring a higher upkeep of the mechanical resistance in time, even if subjected to the contact with chemical and oxidizing agents. Moreover, a chemical process that does not require the achievement of high temperatures and pressures is made; for this reason, the dimensional stability results improved.

Regarding the mechanical resistance, we report the results of some tests carried out in laboratory:

	TENSILE S	BURST TEST	
amplions of the Lepistedive	At 22,8°C	At 82,2°C	At 82,2°C
Pe-Xb	21,1 MPa	12,5 MPa	25,8 bar
Pe-Xa	16,8 MPa	11,4 MPa	21,0 bar
Pe-Xc	19,0 MPa	10,3 MPa	21,7 bar

All pipes of the Giacotherm series are extruded with an external oxygen barrier in EVOH, complying with DIN 4726 standard.

Eng. Marco Rosa Brusin

Technical Manager

Marco Rosa Osculson



GIACOMINI S.p.A.
Tel. (+39) 0322 923111
Fax (+39) 0322 96256
info@giacomini.com
www.giacomini.com

Sede legale ed amministrativa:
Via per Alzo, 39 - 28017 San Maurizio d'Opaglio (NO) ITALIA
R.E.A. della CCIJAA di Novara n. 194845
RIVA 01792290031 - Codice Fiscale 01856080062
Identificativo IVA IT 01792290031
Capitale Sociale: € 50.666.520 i.v.

Società soggetta a direzione e coordinamento della Alberto Giacomini Holding S a s. di Alberto Giacomini



STATEMENT

The PE-X pipe supplied by Giacomini S.p.A. is manufactured in accordance with EN ISO 15875 standard. The subject pipe is produced starting from high density granular polyethylene (HDPE), and submitted to crosslinking process, according to the silane method.

The pipe is designed for 50 years of use, at the following working conditions (Table 1 of the above-mentioned standard):

Class	Working Temperature T _o [°C]	Time at T _O [years]	T _{MAX} [°C]	Time at T _{MAX} [years]	Abnormal temperature due to wrong working T _M [°C]	Time at T _M [hours]	Application range
1 or bedraious en	60	49	80	1	95	100	Sanitary hot water (60°C)
2	70	49	80	1	95	100	Sanitary hot water (70°C)
4	20 40 60	2,5 20 25	70	2,5	100	100	Floor heating systems and low temperature radiators
5	20 60 80	14 25 10	90	1	100	100	High temperature radiators

Giacomini guarantees the pipe, in accordance with its own sale conditions and with the prescriptions of the Legislative Decree no.172 21/05/2004, providing that:

- The pipe has the manufacturing date and the customer can prove that, it has been purchased from Giacomini or from a Giacomini's distributor, showing the related sale documents.
- The evidence of the production defect is necessary, in order to make the free replacement of the pipe.

Warranty does not cover following cases:

- When use conditions do not correspond to the ones prescribed by the Company.
- When the pipe is used with incompatible products.
- When the assembly directions have not been followed.
- When the pipe shows an evidence of imperfection before the installation, or when the defects did show up during the running test, and the pipe has not been replaced before proceeding with the installation;
- When the pipe has been manipulated in a different manner as regards to the prescriptions, or installed with tools different from those ones authorized by Giacomini.