

HOW to use ETS5 plugin SE

In this guide we will provide the necessary steps in order to enable Carel ETS5_SE plugin.

Prerequisites:

Carel_plugin_ETS5_SE.knxproj

ETS 5.5.2 or above

A valid license of ETS5 (DEMO version does not allow the proper import of the knxprj file)


Differences between Carel_plugin_ETS5.knxproj and Carel_plugin_ETS5_SE.knxproj:

- 1) Not necessary Install Patch (Install_CRLets5.bat, in previous document refer to point 3)
- 2) New name, from "CAREL Virtual Device" to "Modbus-KNX Gateway Large System"
- 3) XML writing is show just at the end of the import xml step, in previous version it was handled row by row
- 4) In case of multiple device reconfiguration, is not necessary anymore restart ETS

STEPS:


1)Open ETS5

Verify version is not DEMO and Compatibly Mode App is enabled:




2) Import Carel_plugin_ETS5_SE.knxproj

Follow the import procedure wizard




Set the Individual Address of the Modbus-KNX Gateway Large System as shown in user manual



3) Install XML project

open Parameter dialog box and select your XML file



Confirm Dialog Box with Yes and wait until message "Connection successfully closed!" appears:

